



Office of the District Fire Officer,
Karnataka Fire and Emergency Services Department
Davanagere Range,
Chitradurga Fire Station Premises,
Medehalli road, Chitradurga- 577 527.

Phone:08194-221900

dfochitradurga.ksfes@ka.gov.in



C.No: 96/School/CC/DFO/2023.

Date: 28-08-2023.

To,

The Secretary,
S.Nijalingappa Educational
& Rural Development trust (Reg),
S. Nijalingappa International School,
Site no.823 & R.Sy.no.86 & 125,
Kuvempunagara, Hosadurga town,
Chitradurga Dist-577527.

Sir,

Sub:-Issue of 'Fire Safety Compliance Certificate' with respect of fire prevention, fighting and evacuation measures maintained / required at "S.Nijalingappa Educational & Rural Development trust (Reg), S. Nijalingappa International School" situated at Site no.823 & Sy.no.86 & 125, Kuvempunagara, Hosadurga town & taluk, Chitradurga Dist-577527.

Ref: 77/School/DFO/2023. dated: 11-08-2023.

With reference to the subject cited above, "Fire Safety Recommendation" was issued wide above reference to the premises of "S.Nijalingappa Educational & Rural Development trust (Reg), S. Nijalingappa International School" situated at Site no.823 & R.Sy.no.86 & 125, Kuvempunagara, Hosadurga town & taluk, Chitradurga Dist-577527. With a condition to fulfill the recommendations and compliance the same within 03 months.

The management "S.Nijalingappa Educational & Rural Development trust (Reg), S. Nijalingappa International School", had requested for the compliance report from our department. In this regard the building was re-inspected by District Fire officer on 28-08-2023 and they have fulfilled all the Fire precautionary measures. and found all the precautionary measures are in good working condition at the time of inspection.

Under the above circumstances the Karnataka Fire & Emergency Services Department is issuing the "Compliance Certificate" to "S.Nijalingappa Educational & Rural Development trust (Reg), S. Nijalingappa International School" situated at Site no.823 & R.Sy.no.86 & 125, Kuvempunagara, Hosadurga town & taluk, Chitradurga Dist-577527. Subject to proper maintenance of fire fighting system in good working condition and at-least 40% of employees should be trained in basic fire fighting at our R.A Mundkur Fire & Emergency Academy, Bannerghatta road, Bengaluru.

This Compliance Certificate is valid till Dated 10-08-2024 and it is renewable.

Yours faithfully

Secretary

Principal

S.Nijalingappa Educational & Rural
Development Trust (R)
Kuvempu Nagar Hosadurga-577 527

S. Nijalingappa International Scho
Affiliation No: 830777
Kuvempu Nagara, Hosadurga-577

DISTRICT FIRE OFFICER
CHITRADURGA DISTRICT